



Protecting, Maintaining and Improving the Health of All Minnesotans

April 2, 2024

Spring Park City Council
c/o Mike Anderson, City Administrator
Spring Park City Hall
4349 Warren Avenue
Spring Park, Minnesota 55384-9711

Dear Council Members:

SUBJECT: Drinking Water Summary of Detect Monitoring, Spring Park, Hennepin County, PWSID 1270053

The following is a summary of results including the most recent sample(s) collected from your public water system in accordance with Minnesota Rules, Chapter 4720.

Results of contaminant(s) detected at the following sample point(s) have triggered quarterly monitoring. Monitoring will continue on a quarterly basis until the Minnesota Department of Health (MDH) determines that results are reliably and consistently below the health risk limit (HRL).

Sampling Site: Treatment Plant #1

Contaminant: cis-1,2-Dichloroethene
HRL: >6.0 µg/L

Table with 5 columns: Date Collected, Results, Units, Sample#, Annual Average. Rows show data for 03/11/2024, 10/20/2023, 08/22/2023, and 05/01/2023.

Contaminant: Trichloroethene (TCE)
HRL: >0.4 µg/L


Table with 5 columns: Date Collected, Results, Units, Sample#, Annual Average. Rows show data for 03/11/2024, 10/20/2023, 08/22/2023, and 05/01/2023.

Spring Park City Council
Page 2
April 2, 2024
PWSID 1270053

All future Volatile Organic Chemical (VOC) samples will be collected and analyzed by the MDH. We will notify you if any action by your system is required.

This report should be placed in your records and a copy maintained on or near the water system premises and available for public inspection for not less than ten (10) years. If you have any questions, please contact David Vaaler at 651/201-4674 or email david.vaaler@state.mn.us.

Sincerely,

A handwritten signature in black ink that reads "Kim Larsen". The signature is written in a cursive style with a large, sweeping initial "K".

Kim Larsen, P.E., Supervisor
Community Public Water Supply Unit
Environmental Health Division
3333 West Division Suite, Suite 212
St. Cloud, Minnesota 56301

KAL:DLV
Enclosure

cc: Water Superintendent
Dorene Fier-Tucker, MN Pollution Control Agency
Michele Mabry, MN Pollution Control Agency
Lee Zettler, MN Department of Agriculture
Brian A. Noma, MDH St. Paul District Office
Lucas Martin, MDH St. Paul District Office